



UK DECLARATION OF CONFORMITY

PMA KS20-1 Series West Pro-16 (Also branded Weishaupt)

This product is manufactured at the premises of West Control Solutions, The Hyde Business Park, Brighton, East Sussex, BN2 4JU, England, UK

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The objects of this declaration are the products identified using the model numbers derived from the tables listed below.

The objects of this declaration are in conformity with the following UK legislation:

Electromagnetic Compatibility Regulations 2016
The Electrical Equipment (Safety) Regulations 2016
The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012

The assessment of conformity has been made using the standards route to compliance. The standards this product is compliant with are listed below: -

BS EN 61326-1:2013 Electrical equipment for measurement, control and laboratory use — EMC Requirements — Part 1: General Requirements

FCC Title 47 Chapter 1A Part 15B RADIO FREQUENCY DEVICES

FCC Title 47 Chapter 1A Part 18 INDUSTRIAL, SCIENTIFIC, AND MEDICAL EQUIPMENT

BS EN55011:2009 + A1:2010 Industrial, scientific and medical equipment – Radio Frequency disturbance characteristics – Limits and methods of measurement

This product has been evaluated as Class A equipment suitable for operation in Industrial Locations against this standard.

WARNING

This is a Class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

UL 61010-1 Edition 3, Safety requirements for electrical equipment for measurement, control and laboratory use; Part 1: General Requirements

BS EN IEC 63000:2018, Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances.

This declaration is made for and on behalf of Fortive by Paul Barber, who has been designated as the responsible person for the purpose of the regulations.

Signature: 
(Paul Barber)

Date of Issue: 24 August 2021

Model Number	KS201	x	x	x	x	x	x	x	0	03
Supply Voltage										
100-240V AC		0								
24VAC/18..30VDC		1								
Base Option										
Transmitter Power Supply - TPS			T							
Heater Current / Remote sepoint mA			H							
Option 1										
Relay (changeover)				R						
Single SSR				A						
Dual SSR				Y						
Linear mA/VDC Output				L						
Option 2										
Not fitted					0					
Relay (switch over)					R					
Dual Relay					D					
Single SSR					A					
Dual SSR					Y					
Option 3										
Not fitted						0				
Relay (changeover)						R				
Single SSR						A				
Dual SSR						Y				
Linear mA/VDC Output						L				
RS485						C				
Option A										
Not fitted							0			
RS485							C			
Dual Isolated digital input							B			
Manual Language										
German								1		
English								2		
French								3		
Brand										
PMA Brand										03